



TYPICAL SECTION
NTS

NOTES:

1. VALVE SHALL BE CUT IN A MINIMUM OF 40 FEET FROM NEW CONNECTION POINT UNLESS OTHERWISE APPROVED BY CARSON CITY WATER UTILITY.
2. CUT OPENING IN PIPE 1/2 INCH LONGER THAN TOTAL LENGTH OF VALVE, INSERT FLG x FLG VALVE USING FLANGED COUPLING ADAPTERS.

| | | | | |
|--------------|-----------|------|---|-------------------|
| NO. | REVISION | DATE | STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION | SECTION |
| 1 | NUT DEPTH | 9/17 | CUT IN GATE VALVE | CARSON CITY |
| | | | | DRAWING NO. |
| | | | | C-3.1.5 (203,307) |
| | | | | DATE |
| APPROVED BY: | | 9/17 | | SEP 2017 |